

2058 111111
Rodney Morris
Amen Sheridan
EPA Walker - Brian spoke 2

Telecon 6-7-2010



Fuel Plaza Underground Storage Tanks
Victoria Matthews to: bird234, sheridan, idj2007

06/04/2010 03:09 PM

AMEN

IDA
Mr. Sheridan and Ms. Walker,

402-837-5391

Reference our conversation today, on the Omaha Tribes Underground storage tanks (USTs) at the Fuel Plaza, in Onawa. After looking over the Fuel Plaza records, we need to discuss temporary closure of the USTs. The procedure and CFR reference are provided below:

- During the last inspection the discrepancy was:
 - Tanks and dispensers were not locked, *in July 09, during*
- Reference 40 CFR 280.70. Temporary Closure, Subpart G Out-of-Service Systems and Closure. When an UST System is temporarily closed, owner and operators should perform the following:
 - Tanks can not have over 1 inch of residue in the tank
 - If tanks are not in use Closed 3 months or more
 - leave vent lines open and functioning
 - Cap and secure all other lines, pumps, manways and dispensers
- 40 CFR 280.31, does not apply since you do not have a corrosion protection (CP) system

fuel residue

*none or lock
turn off electricity or put on lock*

I looked forward to continuing our conversation on Monday June 7 at 9:00 a.m.

Thank you for your assistance.

Should be covered

Victoria Eastin Matthews
Environmental Protection Specialist
Environmental Protection Agency (EPA)
AWMD/Storage Tank Oil Pollution Branch
901 N. 5th Street, Kansas City, KS 66101
Ofc: (913) 551-7353
Fax: (913) 551-9353

*lock dispensers -
are pumps still in place
fill parts must be locked -
product must do release detection*

~~~~~  
This message, including any attachments, may contain confidential information intended for a specific individual and purpose, and may be protected by law. If you are not the intended recipient, please notify the sender by e-mail or telephone immediately, and then immediately delete this message, or the taking of any action based on it, by any unintended recipient is strictly prohibited.

*Cap + Secure all lines -*

*manways*

*manways*

*also - will send a letter when things are done*

We are not closing.

To Reopen ~~are~~ in 60 days  
↓  
CFO

12

Bag over nozzle dispenser,

Any product? No, ~~if product~~ -

If yes, need to do release detector w/ATG. or  
get product out of tank.

- Lock dispenser

- Lock where fill tubes

perform state when you become active.

---

Do you have contacts w/STATES - yes,

Env. Quality Craig Thompson.

Financial Assurance - Self Assurance, says they have  
paperwork.